

John W. Johnson
Co-President
Architect

Brian F. Zita
Co-President
Architect

John B. Hicks
Vice President

Cecil R. Spencer
Vice President

Regional Managers

Jesse E. Macias

Roy W. Pedro

Alan K. Shimabukuro

John W. Strobel

Blythe R. Wilson

October 15, 2004
Amended 12/14/04

Blueline Technologies
265 Burns Drive
Yuba City, CA 95991

ATT: Brian Henry

**RE: STATE REGISTERED PROFESSIONAL ENGINEER APPROVAL
CCR Title 23 Division 3, Chapter 1, Section 263(h) Secondary Containment**


CPT-201 CORROSION PROOFING SPRAY

I have examined and reviewed the following on SEI Chemical CPT-201 Corrosion Proof Spray for use on Stainless Steel Worm Clamps used with Blueline penetration fittings on underground single or double wall secondary sumps.

1. SEI Chemical SET CORROSION PROOF SOLVENT BASE COAT CPT-201 Corrosion Prevention Technology. (3)
2. SEI CORROSION PREVENTION TECHNOLOGY (1)
3. Blueline penetration fitting – housing, Pellethane reducer and two stainless steel CPT-201 sprayed worm drive hose clamps.
4. Blueline Installation Instructions Section 19 Kwik Fit Rigid and Conduit Installation Instructions.
5. Metal band clamps must be sprayed on both sides with CRT-201 in accordance with Note 1 of installation instructions in Item 4 above.

Upon review of the materials, construction and application it is my opinion and conclusion that sound engineering design and engineering of this product will provide satisfactory protection for the stainless steel bands.

Established 1966



JAMES H. RAY
Sr. Civil Engineer



Offices

ANAHEIM, CA

BELLEVUE, WA

CAMAS, WA

MARTINEZ, CA

PETALUMA, CA

ROSEVILLE, CA

SCOTTSDALE, AZ